

Utah Department of Environmental Quality

Division of Drinking Water

Public Water System Inventory Report

Run Date:
08/04/2011 12:03 pm

PWS ID: UTAH11037 **Name:** MOUNTAIN VIEW SSD
Legal Contact: MT. VIEW SPEC. SERV. DIST
BETTY WALKER
Address: PO BOX 1202
CEDAR CITY, UT 84721
Phone Number: 435-586-6118
City Served (Area):
County: IRON COUNTY
System Type: Community
Activity Status Cd: Active
Population: 103
Rating: Approved
Rating Date: 10/01/1985
Activity Status: Active
Last Inv Update: 01/06/2011
Last Snty Srv Dt: 11/02/2009
Surveyor: JOHN GALLIS
Oper Period: 1/1 to 12/31

Gal/Day **Gal/Min**

Avg Daily Prod:

Total Dsgn Cap:

Total Emerg Cap:

Contacts

Contact Type	Name	Title	Phone Numbers		Email Address
			Office	Emergency	
AC	WALKER, BETTY		435-867-4252		

Service Connections

Connection Type	Meter Type Code	Meter Size	Number Connections
Residential	Unmetered	0	60
			60 Total Svc Connections

Storage

Total Storage: 130,000 GAL **Number of Units:** 2 **Adequate Capacity:** NO

No.	Name	Type	Effective Volume	Constr Matrl	Overflow Elev	Activity Status	Press'd
ST001	100000 TANK	Ground	110,000 GAL	Steel		A	NO
ST002	20000 TANK	Ground	20,000 GAL	Steel		A	NO

Distribution System

Pump Type	Total Dyn Head ft H2O	P.S.I.	Pressure Adequate	Cross Connection	Auhority Statement
No					

Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Location Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS001	WELL 8 IN	Active	WL	8	120 GPM	150 GPM	Yes	GW	Permanent	1/1 to 12/31	
WS002	WELL #2	P	WL				No	GW			

*Reports measured flow for wells, approved design capacity for all other sources.